



FREEHOLD REGIONAL HIGH SCHOOL DISTRICT

*Sean P. Boyce, CPA
Assistant Superintendent for
Business Administration/
Board Secretary*

*11 Pine Street
Englishtown, NJ 07726
(732) 792-7300 ext. 8519
Fax: (732) 446-5192*

June 21, 2017

Freehold Regional High School District
Manalapan High School
20 Church Lane
Englishtown, NJ 07726

Dear Manalapan High School Community,

Our school system is committed to protecting student, teacher and staff health. To protect our community and be in compliance with the Department of Education regulations, the Freehold Regional High School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Manalapan High School has implemented immediate measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlets until re-testing and/or remedial action showed lead concentrations were below the action level.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we identified and tested all drinking water and food preparation outlets. Of the 74 samples taken, all but 13 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The following table identifies the drinking water outlets that tested above the 15 µg/l action level for lead, the actual lead level, and the steps Freehold Regional High School District has taken to reduce the levels of lead at these locations, if necessary.

Location	First Draw Result in µg/l (ppb)	Resampling Results in µg/l (ppb)	Remedial Action	Remediation Results in µg/l (ppb)
Team Room A Drinking Water Fountain ID# MAN-01-TEAM RM A-DW	56.3	N/A	Outlet taken out of service.	N/A
Kitchen Kettle 2 ID# MAN-01-KIT-KT2	2540	N/A	Outlet taken out of service.	N/A
Hallway Drinking Water Fountain @ E106 ID# MAN-01-H E106-DW	38.3	First Draw Result: 44 Flush Draw Result: 14.2	Fixture and associated plumbing replaced to the wall.	First Draw Result: <2.0

Location	First Draw Result in $\mu\text{g/l}$ (ppb)	Resampling Results in $\mu\text{g/l}$ (ppb)	Remedial Action	Remediation Results in $\mu\text{g/l}$ (ppb)
				Flush Draw Result: <2.0
Hallway Drinking Water Fountain @ D117 ID# MAN-01-H D117-DW1	35.5	N/A	Outlet taken out of service.	N/A
Hallway Drinking Water Fountain @ D117 ID# MAN-01-H D117-DW2	23.3	N/A	Outlet taken out of service.	N/A
Classroom Faucet in D115 ID# MAN-01-D115-CF	29.5	N/A	Outlet taken out of service.	N/A
Hallway Drinking Water Fountain @ C218 ID# MAN-02-H C218-DW	80.7	N/A	Outlet taken out of service.	N/A
Hallway Drinking Water Fountain @ E206 ID# MAN-02-H E206-DW	39.4	First Draw Result: 67.5 Flush Draw Result: 8.5	Fixture and associated plumbing replaced to the wall.	First Draw Result: <2.0 Flush Draw Result: <2.0
Hallway Drinking Water Fountain @ D223 ID # MAN-02-H D223-DW	21.8	First Draw Result: 18.2 Flush Draw Result: <2.0	Fixture and associated plumbing replaced to the wall.	First Draw Result: <2.0 Flush Draw Result: <2.0
Prep Classroom Faucet in G202 ID# MAN-02-G202 PREP-CF	24.1	N/A	Location will remain on for non-drinking purpose. Posted signage "DO NOT DRINK – SAFE FOR HANDWASHING ONLY"	N/A
Prep Classroom Faucet 1 in G203 ID# MAN-02-G203 PREP-CF1	43.2	N/A	Location will remain on for non-drinking purpose. Posted signage "DO NOT DRINK – SAFE FOR HANDWASHING ONLY"	N/A
Prep Classroom Faucet 2 in G203 ID# MAN-02-G203 PREP-CF2	28.2	N/A	Location will remain on for non-drinking purpose. Posted signage "DO NOT DRINK – SAFE FOR HANDWASHING ONLY"	N/A
Outside Hose Bib ID# MAN-01-OUTSIDE-HB	29	First Draw Result: 9.7 Flush Draw Result: <2.0	None required.	N/A

Additional Resources

- A copy of the test results is available for inspection by the public, including students, teachers, other school personnel and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. at the district's administrative office located at the above listed address. The results are also posted on our website at www.frhsd.com.
- The attached ***Drinking Water Facts: Lead*** flyer issued by the New Jersey Department of Health provides an additional information on lead in drinking water.
- United States Environmental Protection Agency – www.epa.gov/lead
- New Jersey Department of Environmental Protection - www.nj.gov/dep/watersupply/dwc-lead-schools.html.

Regards,

A handwritten signature in blue ink, appearing to read 'SB', followed by a horizontal line.

Sean Boyce, CPA
Assistant Superintendent for Business
Freehold Regional High School District