



FREEHOLD REGIONAL HIGH SCHOOL DISTRICT

*Sean P. Boyce, CPA
Assistant Superintendent for
Business Administration/
Board Secretary*

*11 Pine Street
Englishtown, NJ 07726
(732) 792-7300 ext. 8519
Fax: (732) 446-5192*

June 21, 2017

Freehold Regional High School District
Marlboro High School
95 North Main Street
Marlboro, NJ 07746

Dear Marlboro High School Community,

Our school system is committed to protecting student, teacher and staff health. To protect our community and be in compliance with the Department of Education regulations, the Freehold Regional High School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Marlboro High School has implemented immediate measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlets until re-testing and/or remedial action showed lead concentrations were below the action level.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we identified and tested all drinking water and food preparation outlets. Of the 53 samples taken, all but five tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l action level for lead, the actual lead level, and the steps Freehold Regional High School District has taken to reduce the levels of lead at these locations, if necessary.

Location	First Draw Result in µg/l (ppb)	Resampling Results in µg/l (ppb)	Remedial Action
Nurse's Faucet ID#: MAR-01-NURSE-NS-P	22.3	First Draw Result: 21.7 Flush Draw Result: <2.0	Remediation completed from the fixture to wall. Remediation sample results: < 2.0
Home EC Faucet 3 ID#: MAR-01-HOME EC A133-EC3	24.4	First Draw Result: 8.6 Flush Draw Result: <2.0	None required.
Home EC Faucet 4 ID#:MAR-01-HOME EC A135-EC4	20.5	First Draw Result: 2.4 Flush Draw Result: 2.2	None required.
Cafeteria Drinking Water Fountain ID#:MAR-01-H CAFE-DW	25.0	First Draw Result: 8.4 Flush Draw Result: 6.6	None required.
Hallway Drinking Water Fountain ID#:MAR-02-H A215-DW	526	None.	Fixture was removed.

Additional Resources

- A copy of the test results is available for inspection by the public, including students, teachers, other school personnel and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. at the district's administrative office located at the above listed address. The results are also posted on our website at www.frhsd.com.
- The attached ***Drinking Water Facts: Lead*** flyer issued by the New Jersey Department of Health provides an additional information on lead in drinking water.
- United States Environmental Protection Agency – www.epa.gov/lead
- New Jersey Department of Environmental Protection - www.nj.gov/dep/watersupply/dwc-lead-schools.html.

Regards,

A handwritten signature in blue ink, appearing to read 'S. Boyce', with a horizontal line extending to the right.

Sean Boyce, CPA
Assistant Superintendent for Business
Freehold Regional High School District