



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Freehold Borough High School, 2 Robertsville Road
PAS Project ID : P22-03289

Matrix : Drinking Water
Report Date : 5/2/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03289-01	Freehold Boro-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 05:47	4/25/22 09:46
P22-03289-02	FBO-1-H MO-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 05:51	4/25/22 09:50
P22-03289-03	FBO-1-MO-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 05:53	4/25/22 10:14
P22-03289-04	FBO-1-Guidance-TL-P	Lead	15.6	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 05:54	4/25/22 10:18
P22-03289-05	FBO-1-Nurse-NS-P	Lead	4.25	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 05:56	4/25/22 10:21
P22-03289-06	FBO-1-Nurse-BF-P	Lead	1.19 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 05:57	4/25/22 10:25
P22-03289-07	FBO-1-H B118-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 05:59	4/25/22 10:29
P22-03289-08	FBO-1-TL B Wing-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:03	4/25/22 10:33
P22-03289-09	FBO-1-TL B Wing-SP-P	Lead	1.42 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:04	4/25/22 10:37
P22-03289-10	FBO-1-H B216-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:10	4/25/22 10:41
P22-03289-11	FBO-1-H B201-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:11	4/25/22 10:45
P22-03289-12	FBN-1-Kitchen-FP-P	Lead	2.13	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:17	4/25/22 10:58
P22-03289-13	FBN-1-Kitchen-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:18	4/25/22 11:02
P22-03289-14	FBN-1-Trainer-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:21	4/25/22 11:06
P22-03289-15	FBN-1-Trainer-CF-P	Lead	1.42 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:22	4/25/22 11:10
P22-03289-16	FBN-1-Trainer-HB/CF-P	Lead	3.07	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:23	4/25/22 11:14
P22-03289-17	FBN-1-C106-CF-P	Lead	8.03	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:25	4/25/22 11:18
P22-03289-18	FBN-1-C104-CF-P	Lead	3.07	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:27	4/25/22 11:23
P22-03289-19	FBN-1-H C104-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:28	4/25/22 11:27
P22-03289-20	FBN-1-B119-FP1-P	Lead	102	ug/L	10	20.0	8.99	15.0 *	SM 3113 B	4/21/22 06:31	4/25/22 14:38
P22-03289-21	FBN-1-B119-FP2-P	Lead	2.13	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:32	4/25/22 11:43
P22-03289-22	FBN-1-B119-FP3-P	Lead	3.55	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:33	4/25/22 11:59
P22-03289-23	FBN-1-B119-SP1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:34	4/25/22 12:03
P22-03289-24	FBN-1-B121-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:35	4/25/22 12:07
P22-03289-25	FBN-1-B122-CF1-P	Lead	46.0	ug/L	5	10.0	4.50	15.0 *	SM 3113 B	4/21/22 06:36	4/25/22 13:44
P22-03289-26	FBN-1-B124-FP-P	Lead	2.60	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:38	4/25/22 12:14
P22-03289-27	FBN-1-5* Dining-KS1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:40	4/25/22 12:26
P22-03289-28	FBN-1-5* Dining-KS2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:41	4/25/22 12:30
P22-03289-29	FBN-1-5* Kitchen-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:42	4/25/22 12:34
P22-03289-30	FBN-1-5* Kitchen-FP1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:43	4/25/22 12:38
P22-03289-31	FBN-1-5* Kitchen-KT1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:44	4/25/22 12:42
P22-03289-32	FBN-1-5* Kitchen-KT2-P	Lead	0.950 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:44	4/25/22 12:46
P22-03289-33	FBN-1-5* Kitchen-FP2-P	Lead	1.19 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:45	4/25/22 12:50
P22-03289-34	FBN-1-5* Kitchen-FP3-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:46	4/25/22 12:54
P22-03289-35	FBN-1-5* Kitchen-FP4-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:47	4/25/22 13:16
P22-03289-36	FBN-1-5* Kitchen-FP5-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:48	4/25/22 13:32
P22-03289-37	FBN-1-5* Kitchen-ST1-P	Lead	3.78	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:50	4/25/22 13:36

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1516

CHAIN OF CUSTODY

Proj# 1079-10

Customer: PARS Environmental
Address: 500 Horizon Drive, Suite 540
 Robbinsville, NJ 08691
Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

School Name: Freehold Borough HS
School Address: 2 Robertsville Road
Sampled By: Jocynn Maloughny
Print Name: Jocynn Maloughny
RESULTS TO: JPerrini@montrose-env.com

Sample #	Sample ID Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
1	Freehold Boro - Field Blank	5:47	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03-89-01
2	FBO-1- H MO - BT - P	5:51	DW	Grab	N	N	1	250 ml Plastic	Lead	-2
3	FBO-1- MO - TL - P	5:53	DW	Grab	N	N	1	250 ml Plastic	Lead	-03
4	FBO-1- Guidance - TL - P	5:54	DW	Grab	N	N	1	250 ml Plastic	Lead	-04
5	FBO-1- Nurse - NS - P	5:56	DW	Grab	N	N	1	250 ml Plastic	Lead	-05
6	FBO-1- Nurse - BF - P	5:57	DW	Grab	N	N	1	250 ml Plastic	Lead	-06
7	FBO-1- H B118 - BT - P	5:59	DW	Grab	N	N	1	250 ml Plastic	Lead	-07
8	FBO-1- TL B Wing - TL - P	6:03	DW	Grab	N	N	1	250 ml Plastic	Lead	-08
9	FBO-1- TL B Wing - SP - P	6:04	DW	Grab	N	N	1	250 ml Plastic	Lead	-09
10	FBO-2- H B216 - BT - P	6:10	DW	Grab	N	N	1	250 ml Plastic	Lead	-10
11	FBO-2- H B201 - BT - P	6:11	DW	Grab	N	N	1	250 ml Plastic	Lead	-11
	New Wing		DW	Grab	N	N	1	250 ml Plastic	Lead	-12
12	FRN-1- kitchen - FP - P	6:17	DW	Grab	N	N	1	250 ml Plastic	Lead	-12
13	FRN-1- kitchen - IM - P	6:18	DW	Grab	N	N	1	250 ml Plastic	Lead	-13
14	FRN-1- Trainer - IM - P	6:21	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03-89-14

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std. PDF Reduce PDF Full EDD

Date/Time Preserved with HNO₃:

Page 1 of 3

Deliverables:

X

MATRIX CODES:

GW = Ground Water, WW = Waste Water, SW = Surface Water,
 DW = Drinking Water, S = Sol, L = Liquid, SD = Sludge,
 B = Blank, K = Solid (specify):

PRESERVATIVE CODES:

0 = Ice 1 = HCl
 2 = H2SO4 3 = NaOH
 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Jocynn Maloughny	[Signature]	PARS	4/21/22
Received:	Collin Oriente	[Signature]	PARS	
Relinquished:	Collin Oriente	[Signature]	PARS	4/21/22
Received:	Lynn Souza	[Signature]	PARS	0945
Relinquished:				
Received:				



CHAIN OF CUSTODY

Proj # 1079-10

Customer: PARS Environmental
Address: 500 Horizon Drive, Suite 540
 Robbinsville, NJ 08691
Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

School Name: Freeland Borough HS
School Address: 2 Robertsville Road
Sampled By: Jolynn Moloughney
Print Name: Jolynn Moloughney
RESULTS TO: JPerrini@montrrose-env.com

Sample #	Sample ID Location	Date/Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
15	FBN-1- Trainer - CF - P	6:22	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03289-15
16	FBN-1- Trainer - HB/CF - P	6:23	DW	Grab	N	N	1	250 ml Plastic	Lead	-16
17	FBN-1- C106 - CF - P	6:25	DW	Grab	N	N	1	250 ml Plastic	Lead	-17
18	FBN-1- C104 - CF - P	6:27	DW	Grab	N	N	1	250 ml Plastic	Lead	-18
19	FBN-1- H C104 - BT - P	6:28	DW	Grab	N	N	1	250 ml Plastic	Lead	-19
20	FBN-1- B119 - FP1 - P	6:31	DW	Grab	N	N	1	250 ml Plastic	Lead	-20
21	FBN-1- B119 - FP2 - P	6:32	DW	Grab	N	N	1	250 ml Plastic	Lead	-21
22	FBN-1- B119 - FP3 - P	6:33	DW	Grab	N	N	1	250 ml Plastic	Lead	-22
23	FBN-1- B119 - SP1 - P	6:34	DW	Grab	N	N	1	250 ml Plastic	Lead	-23
24	FBN-1- B121 - TL - P	6:35	DW	Grab	N	N	1	250 ml Plastic	Lead	-24
25	FBN-1- B122 - CF1 - P	6:36	DW	Grab	N	N	1	250 ml Plastic	Lead	-25
26	FBN-1- B124 - FP - P	6:38	DW	Grab	N	N	1	250 ml Plastic	Lead	-26
27	FBN-1- 5* Dining - KS1 - P	6:40	DW	Grab	N	N	1	250 ml Plastic	Lead	-27
28	FBN-1- 5* Dining - KS2 - P	6:41	DW	Grab	N	N	1	250 ml Plastic	Lead	-28
29	FBN-1- 5* Kitchen - 1m - P	6:42	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03289-29

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std. PDF Reduce PDF Full EDD

Date/Time Preserved with HNO₃:

Page 2 of 3

Deliverables:

X

MATRIX CODES:
 GW = Ground Water, WW = Waste Water, SW = Surface Water,
 DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge,
 B = Blank, K = Solid (specify):

PRESERVATION CODES:
 0 = Ice 1 = HCl
 2 = H2SO4 3 = NaOH
 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Jolynn Moloughney	[Signature]	PARS	4/21/22
Received:	Collin Oriente	[Signature]	PARS	
Relinquished:	Collin Oriente	[Signature]	PARS	4/21/22
Received:	Lynn Souza	[Signature]	PARS	0945
Relinquished:				
Received:				



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

CHAIN OF CUSTODY

Proj # 1079-10

Customer: PARS Environmental
 Address: 500 Horizon Drive, Suite 540
 Robbinsville, NJ 08691
 Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

School Name: Freehold Borough HS
 School Address: 2 Roberts Hill Road
 Sampled By: Joynn Moloughney
 Print Name: Joynn Moloughney
 RESULTS TO: JPerrini@montrose-env.com

Sample #	Sample ID Location	Date Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
30	FBN-1- 5* kitchen - FP1-P	6:43	DW	Grab	N	N	1	250 ml Plastic	Lead	032-03289-30
31	FBN-1- 5* kitchen - KT1-P	6:44	DW	Grab	N	N	1	250 ml Plastic	Lead	-31
32	FBN-1- 5* kitchen - KT2-P	6:44	DW	Grab	N	N	1	250 ml Plastic	Lead	-32
33	FBN-1- 5* kitchen - FP2-P	6:45	DW	Grab	N	N	1	250 ml Plastic	Lead	-33
34	FBN-1- 5* kitchen - FP3-P	6:46	DW	Grab	N	N	1	250 ml Plastic	Lead	-34
35	FBN-1- 5* kitchen - FP4-P	6:47	DW	Grab	N	N	1	250 ml Plastic	Lead	-35
36	FBN-1- 5* kitchen - FP5-P	6:48	DW	Grab	N	N	1	250 ml Plastic	Lead	-36
37	FBN-1- 5* kitchen - ST1-P	6:50	DW	Grab	N	N	1	250 ml Plastic	Lead	032-03289-37
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std. PDF Reduce PDF Full EDD Date/Time Preserved with HNO₃

Page 3 of 3

Deliverables:

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Joynn Moloughney	[Signature]	PARS	4/21/22
Received:	Collin Oriente	[Signature]	PARS	
Relinquished:	Collin Oriente	[Signature]	PARS	4/21/22
Received:	Lynn Souza	[Signature]	PAS	0945
Relinquished:				
Received:				