



### CERTIFICATE OF ANALYSIS

**Customer :** PARS Environmental  
500 Horizon Drive, Suite 540  
Robbinsville Twp, NJ 08691

**Project ID :** Freehold Township School, Freehold, NJ  
**PAS Project ID :** P22-03288

**Matrix :** Drinking Water  
**Report Date :** 4/28/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03288-01	FHS-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:03	4/25/22 11:18
P22-03288-02	FHS-1-Home Ec B105-EC1-P	Lead	1.12 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:04	4/25/22 11:22
P22-03288-03	FHS-1-Home Ec B105-EC2-P	Lead	1.12 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:05	4/25/22 11:57
P22-03288-04	FHS-1-Home Ec B105-EC3-P	Lead	1.19 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:06	4/25/22 12:01
P22-03288-05	FHS-1-Home Ec B105-EC4-P	Lead	0.910 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:07	4/25/22 12:04
P22-03288-06	FHS-1-Home Ec B105-EC5-P	Lead	1.05 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:08	4/25/22 12:08
P22-03288-07	FHS-1-Home Ec B105-EC6-P	Lead	1.05 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:09	4/25/22 12:12
P22-03288-08	FHS-1-Home Ec B103-EC1-P	Lead	4.24	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:10	4/25/22 12:15
P22-03288-09	FHS-1-Home Ec B103-EC2-P	Lead	5.07	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:11	4/25/22 12:19
P22-03288-10	FHS-1-Home Ec B103-EC3-P	Lead	2.37	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:12	4/25/22 12:23
P22-03288-11	FHS-1-Home Ec B103-EC4-P	Lead	1.60 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:13	4/25/22 12:26
P22-03288-12	FHS-1-Home Ec B103-EC5-P	Lead	3.06	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:14	4/25/22 12:30
P22-03288-13	FHS-1-Home Ec B103-EC6-P	Lead	1.81 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:15	4/25/22 12:41
P22-03288-14	FHS-1-Custodial-TL-P	Lead	1.05 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:17	4/25/22 12:45
P22-03288-15	FHS-1-Trainer-TL-P	Lead	0.980 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:18	4/25/22 12:49
P22-03288-16	FHS-1-Trainer-HB-P	Lead	3.48	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:19	4/25/22 12:53
P22-03288-17	FHS-1-Trainer-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:20	4/25/22 12:56
P22-03288-18	FHS-1-Aux Gym-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:21	4/25/22 13:00
P22-03288-19	FHS-1-Faculty Serve-FP-P	Lead	1.81 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:23	4/25/22 13:04
P22-03288-20	FHS-1-Kitchen-FP1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:24	4/25/22 13:07
P22-03288-21	FHS-1-Kitchen-FP2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:25	4/25/22 13:11
P22-03288-22	FHS-1-Kitchen-SP-P	Lead	1.05 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:27	4/25/22 13:32
P22-03288-23	FHS-1-Nurse-NS1-P	Lead	6.04	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:28	4/25/22 13:36
P22-03288-24	FHS-1-Nurse-NS2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:29	4/25/22 13:39
P22-03288-25	FHS-1-Nurse-BF-P	Lead	0.910 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:30	4/25/22 13:43
P22-03288-26	FHS-1-Main Office-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:31	4/25/22 13:46
P22-03288-27	FHS-1-Guidance-TL-P	Lead	0.910 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:33	4/25/22 13:50
P22-03288-28	FHS-1-A101-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:35	4/25/22 13:54
P22-03288-29	FHS-1-A101-IM-P	Lead	0.910 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:36	4/25/22 13:57
P22-03288-30	FHS-1-D100-CF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:37	4/25/22 14:12
P22-03288-31	FHS-1-H D101-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:40	4/25/22 14:16
P22-03288-32	FHS-1-A/V-TL-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:41	4/25/22 14:19
P22-03288-33	FHS-1-H C100-BT-P	Lead	0.910 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:42	4/25/22 14:42
P22-03288-34	FHS-1-C104-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:44	4/25/22 14:53
P22-03288-35	FHS-2-C210 Prep-CF-P	Lead	4.17	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:50	4/25/22 14:57
P22-03288-36	FHS-2-C212 Prep-CF-P	Lead	4.17	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:52	4/25/22 15:00
P22-03288-37	FHS-2-H G201-BT-P	Lead	1.05 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:53	4/25/22 15:04
P22-03288-38	FHS-2-G203 Prep-CF-P	Lead	8.81	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:54	4/25/22 15:07
P22-03288-39	FHS-2-G204 Prep-CF-P	Lead	17.9	ug/L	2	4.00	1.80	15.0 *	SM 3113 B	4/21/22 06:55	4/25/22 15:11

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- \* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies ■ Healdsburg ■ Fontana ■ Murfreesboro

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08785 PHONE 732-914-1515 FAX 732-914-1516

Proj #  
1079-10

**CHAIN OF CUSTODY**

**Customer:** PARS Environmental  
**Address:** 500 Horizon Drive, Suite 540  
 Robbinsville, NJ 08691  
**Phone:** (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

**School Name:** Freehold Twp School  
**School Address:** Freehold NJ  
**Sampled By:** Jessica Perrini  
**Print Name:** Jessica Perrini  
**RESULTS TO:** JPerrini@montrose-env.com

Sample #	Sample ID Location	Date: 4/21/22 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
1	FHS- Field Blank	6:03	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03288-01
2	FHS-1- Home EC B105-EC1-D	6:04	DW	Grab	N	N	1	250 ml Plastic	Lead	-02
3	FHS-1- Home EC-B105-EC2-P	6:05	DW	Grab	N	N	1	250 ml Plastic	Lead	-03
4	FHS-1- Home EC-B105-EC3-P	6:06	DW	Grab	N	N	1	250 ml Plastic	Lead	-04
5	FHS-1- Home EC-B105-EC4-P	6:07	DW	Grab	N	N	1	250 ml Plastic	Lead	-05
6	FHS-1- Home EC-B105-EC5-P	6:08	DW	Grab	N	N	1	250 ml Plastic	Lead	-06
7	FHS-1- Home EC B105-EC6-P	6:09	DW	Grab	N	N	1	250 ml Plastic	Lead	-07
8	FHS-1- Home EC-B103-EC1-P	6:10	DW	Grab	N	N	1	250 ml Plastic	Lead	-08
9	FHS-1- Home EC B103-EC2-P	6:11	DW	Grab	N	N	1	250 ml Plastic	Lead	-09
10	FHS-1- Home EC B103-EC3-P	6:12	DW	Grab	N	N	1	250 ml Plastic	Lead	-10
11	FHS-1- Home EC B103-EC4-P	6:13	DW	Grab	N	N	1	250 ml Plastic	Lead	-11
12	FHS-1- Home EC B103-EC5-P	6:14	DW	Grab	N	N	1	250 ml Plastic	Lead	-12
13	FHS-1- Home EC B103-EC6-P	6:15	DW	Grab	N	N	1	250 ml Plastic	Lead	-13
14	FHS-1- Custodial-TL-P	6:17	DW	Grab	N	N	1	250 ml Plastic	Lead	-14
15	FHS-1- Triuner-TL-P	6:18	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03288-15

SAMPLES REC'D PRESERVED WITH HNO<sub>3</sub> (e)

Page of Deliverables: PDF Std.  PDF Reduce  PDF Full  EDD  Date/Time Preserved with HNO<sub>3</sub>: \_\_\_\_\_

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATIVE CODES:** 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name	Signature	Company	Date + Time
Relinquished:	Jessica Perrini	<i>Jessica Perrini</i>		4/21/22
Received:	Alex Godart	<i>Alex Godart</i>		
Relinquished:	Alex Godart	<i>Alex Godart</i>		4/21/22
Received:	LYNN Souza	<i>Lynn Souza</i>	PARS	0945
Relinquished:				
Received:				



Proj #  
1079-10

**CHAIN OF CUSTODY**

**Customer:** PARS Environmental  
**Address:** 500 Horizon Drive, Suite 540  
 Robbinsville, NJ 08691  
**Phone:** (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

**School Name:** Freehold Twp Schol  
**School Address:** Freehold NJ  
**Sampled By:** Jessica Perrini  
**Print Name:** Jessica Perrini  
**RESULTS TO:** JPerrini@montrose-env.com

Sample #	Sample ID Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
16	FHS-1 Trainer-MB-P	6:19	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03288-16
17	FHS-1 Trainer-IM-P	6:20	DW	Grab	N	N	1	250 ml Plastic	Lead	-17
18	FHS-1-AuxGym-BT-P	6:21	DW	Grab	N	N	1	250 ml Plastic	Lead	-18
19	FHS-1-Faculty Serve-FP-P	6:22	DW	Grab	N	N	1	250 ml Plastic	Lead	-19
20	FHS-1-Kitchen-FP1-P	6:24	DW	Grab	N	N	1	250 ml Plastic	Lead	-20
21	FHS-1-Kitchen FP2-P	6:25	DW	Grab	N	N	1	250 ml Plastic	Lead	-21
22	FHS-1-Kitchen-SP-P	6:27	DW	Grab	N	N	1	250 ml Plastic	Lead	-22
23	FHS-1-Nurse-NS1-P	6:28	DW	Grab	N	N	1	250 ml Plastic	Lead	-23
24	FHS-1-Nurse-NS2-P	6:29	DW	Grab	N	N	1	250 ml Plastic	Lead	-24
25	FHS-1-Nurse-BF-P	6:30	DW	Grab	N	N	1	250 ml Plastic	Lead	-25
26	FHS-1-Main office-TL-P	6:31	DW	Grab	N	N	1	250 ml Plastic	Lead	-26
27	FHS-1-Guidance-TL-P	6:33	DW	Grab	N	N	1	250 ml Plastic	Lead	-27
28	FHS-1-A101-TL-P	6:35	DW	Grab	N	N	1	250 ml Plastic	Lead	-28
29	FHS-1-A101-IM-P	6:36	DW	Grab	N	N	1	250 ml Plastic	Lead	-29
30	FHS-1-D100-CF-P	6:37	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03288-30

SAMPLES REC'D PRESERVED WITH HNO<sub>3</sub>

PDF Std.  PDF Reduce  PDF Full  EDD  Date/Time Preserved with HNO<sub>3</sub>

Page of Deliverables:

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATIVE CODES:** 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Jessica Perrini	[Signature]		4/21/22
Received:	Alex Godart	[Signature]		
Relinquished:	Alex Godart	[Signature]		4/21/22
Received:	Lyan Souza	[Signature]	PARS	09:45
Relinquished:				
Received:				



Specialties in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1518 FAX 732-914-1516

Proj #  
1079-10

**CHAIN OF CUSTODY**

Customer: PARS Environmental  
 Address: 500 Horizon Drive, Suite 540  
 Robbinsville, NJ 08691  
 Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

School Name: Freehold Twp School  
 School Address: Freehold NJ  
 Sampled By: Jessica Perrini  
 Print Name: Jessica Perrini  
 RESULTS TO: JPerrini@montrose-env.com

Sample #	Sample ID Location	Date / / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
31	FHS-1- HD101 - BT-P	6:40	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03288-31
32	FHS-1- A/V - TL - TL-P	6:41	DW	Grab	N	N	1	250 ml Plastic	Lead	-32
33	FHS-1- HC100- BT-P	6:42	DW	Grab	N	N	1	250 ml Plastic	Lead	-33
34	FHS-1- C104- TL-P	6:44	DW	Grab	N	N	1	250 ml Plastic	Lead	-34
35	FHS-2- C210 Prep- CF-P	6:50	DW	Grab	N	N	1	250 ml Plastic	Lead	-35
36	FHS-2- C212 Prep- CF-P	6:52	DW	Grab	N	N	1	250 ml Plastic	Lead	-36
37	FHS-2- HG201 - BT-P	6:53	DW	Grab	N	N	1	250 ml Plastic	Lead	-37
38	FHS-2- G203 Prep- CF-P	6:54	DW	Grab	N	N	1	250 ml Plastic	Lead	-38
39	FHS-2 - G204 Prep- CF-P	6:55	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03288-39
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	

SAMPLES REC'D PRESERVED WITH HNO<sub>3</sub> (P)

PDF Std.  PDF Reduce  PDF Full  EDD  Date/Time Preserved with HNO<sub>3</sub>

Page of Deliverables:

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATIVE CODES:** 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Jessica Perrini	[Signature]		4/21/22
Received:	Alex Godart	[Signature]		
Relinquished:	Alex Godart	[Signature]		4/21/22
Received:	Lynn Souza	[Signature]	PAS	0945
Relinquished:				
Received:				