



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Howell High School, 405 Squankum Yellowbrook
PAS Project ID : P22-03290

Matrix : Drinking Water
Report Date : 5/2/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03290-01	HHS-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:00	4/25/22 13:06
P22-03290-02	HHS-1-Build Ground-TF-P	Lead	72.1	ug/L	20	40.0	18.0	15.0 *	SM 3113 B	4/21/22 06:01	4/25/22 13:42
P22-03290-03	HHS-1-Custodial Break-BF-P	Lead	11.7	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:02	4/25/22 14:46
P22-03290-04	HHS-1-Kit-FP1-P	Lead	2.75	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:04	4/25/22 14:50
P22-03290-05	HHS-1-Kit-FP2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:05	4/25/22 14:54
P22-03290-06	HHS-1-Kit-FP3-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:06	4/25/22 14:58
P22-03290-07	HHS-1-Cafe-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:08	4/25/22 15:03
P22-03290-08	HHS-1-H B104-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:10	4/25/22 15:07
P22-03290-09	HHS-1-Trainers Rm-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:12	4/25/22 15:11
P22-03290-10	HHS-1-Trainers Rm-TF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:13	4/25/22 15:23
P22-03290-11	HHS-1-Guidance-TF-P	Lead	1.25 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:15	4/25/22 15:27
P22-03290-12	HHS-1-A109-CF-P	Lead	1.04 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:17	4/25/22 15:31
P22-03290-13	HHS-1-A107-CF1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:18	4/25/22 15:35
P22-03290-14	HHS-1-A107-CF2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:20	4/25/22 14:42
P22-03290-15	HHS-1-Home Ec A105-EC1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:21	4/25/22 14:46
P22-03290-16	HHS-1-Home Ec A105-EC2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:22	4/25/22 14:50
P22-03290-17	HHS-1-Home Ec A105-EC3-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:24	4/25/22 14:54
P22-03290-18	HHS-1-Home Ec A105-EC4-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:26	4/25/22 14:59
P22-03290-19	HHS-1-Home Ec A105-EC5-P	Lead	1.19 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:27	4/25/22 15:03
P22-03290-20	HHS-1-Home Ec A105-EC6-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:28	4/25/22 15:07
P22-03290-21	HHS-1-H A117-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:30	4/25/22 15:11
P22-03290-22	HHS-1-MO-TF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:32	4/25/22 15:23
P22-03290-23	HHS-1-Faculty Rm-TF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:34	4/25/22 13:48
P22-03290-24	HHS-1-Faculty Rm-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:35	4/25/22 14:00
P22-03290-25	HHS-1-Nurse-NS-P	Lead	2.60	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:40	4/25/22 14:04
P22-03290-26	HHS-1-Nurse-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:42	4/25/22 14:08
P22-03290-27	HHS-2-H C212-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:44	4/25/22 14:12
P22-03290-28	HHS-2-C217 Prep-CF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 06:46	4/25/22 14:16

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



CHAIN OF CUSTODY

1079-10

Customer: PARS Environmental
Address: 500 Horizon Drive, Suite 540
 Robbinsville, NJ 08691
Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Parrini

School Name: Howell High School
School Address: 405 Squaw Run yellow/brown
Sampled By: Marissa Weinstein
Print Name: Marissa Weinstein
RESULTS TO: JPerrini@montrose-env.com

Sample #	Sample ID Location	Date/Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Fiber Present	# Containers	Glass or Plastic	Analysis	LAB ID
1	HHS-FIELD BLANK	4/21/22 6:00	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03280-01
2	HHS-1-BUILD GROUNDS -TF-P	6:01	DW	Grab	N	N	1	250 ml Plastic	Lead	-02
3	HHS-1-CUSTODIAL BREAK-BFP	6:02	DW	Grab	N	N	1	250 ml Plastic	Lead	-03
4	HHS-1-KIT-FP1-P	6:04	DW	Grab	N	N	1	250 ml Plastic	Lead	-04
5	HHS-1-KIT-FP2-P	6:05	DW	Grab	N	N	1	250 ml Plastic	Lead	-05
6	HHS-1-KIT-FP3-P	6:06	DW	Grab	N	N	1	250 ml Plastic	Lead	-06
7	HHS-1-CAFE-BT-P	6:08	DW	Grab	N	N	1	250 ml Plastic	Lead	-07
8	HHS-1-H BIO4-BT-P	6:10	DW	Grab	N	N	1	250 ml Plastic	Lead	-08
9	HHS-1-TRAINERS RM-IM-P	6:12	DW	Grab	N	N	1	250 ml Plastic	Lead	-09
10	HHS-1-TRAINERS RM-TF-P	6:13	DW	Grab	N	N	1	250 ml Plastic	Lead	-10
11	HHS-1-GUIDANCE-TF-P	6:15	DW	Grab	N	N	1	250 ml Plastic	Lead	-11
12	HHS-1-A109-CF-P	6:17	DW	Grab	N	N	1	250 ml Plastic	Lead	-12
13	HHS-1-A107-CF1-P	6:18	DW	Grab	N	N	1	250 ml Plastic	Lead	-13
14	HHS-1-A107-CF2-P	6:20	DW	Grab	N	N	1	250 ml Plastic	Lead	-14
15	HHS-1-HOME EC A105-EC1-P	6:21	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03280-15

SAMPLES REC'D PRESERVED WITH HNO₃ (P2)

PDF Std. PDF Reduce PDF Full EDD Date/Time Preserved with HNO₃

Page 1 of 2 Deliverables:

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Marissa Weinstein	<i>Marissa Weinstein</i>	PARS	4/21/22
Received:	Collin Oriente	<i>Collin Oriente</i>	PARS	
Relinquished:	Collin Oriente	<i>Collin Oriente</i>	PARS	4/21/22
Received:	Lynn Souza	<i>Lynn Souza</i>	PARS	0945
Relinquished:				
Received:				



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal
PRECISION ANALYTICAL SERVICES, INC.

2181 WHITESVILLE ROAD TOMS RIVER, NJ 08785 PHONE 732-914-1516 FAX 732-914-1616

CHAIN OF CUSTODY

1079-10

Customer: PARS Environmental
Address: 500 Horizon Drive, Suite 540
 Robbinsville, NJ 08691
Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

School Name: Howell High School
School Address: 406 Squawank Rd Yellow Bank NJ
Sampled By: Marissa Weinstein
Print Name: Marissa Weinstein
RESULTS TO: JPerrini@montrose-env.com

Sample #	Sample ID Location	Date/Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
16	HHS-1-HOME EC AIDS-EC2-P	6:22	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03290-16
17	HHS-1-HOME EC AIDS-EC3-P	6:24	DW	Grab	N	N	1	250 ml Plastic	Lead	-17
18	HHS-1-HOME EC AIDS-EC4-P	6:26	DW	Grab	N	N	1	250 ml Plastic	Lead	-18
19	HHS-1-HOME EC AIDS-EC5-P	6:27	DW	Grab	N	N	1	250 ml Plastic	Lead	-19
20	HHS-1-HOME EC AIDS-EC6-P	6:28	DW	Grab	N	N	1	250 ml Plastic	Lead	-20
21	HHS-1-H A117-BT-P	6:30	DW	Grab	N	N	1	250 ml Plastic	Lead	-21
22	HHS-1-MO-TF-P	6:32	DW	Grab	N	N	1	250 ml Plastic	Lead	-22
23	HHS-1-FACULTY RM-TF-P	6:34	DW	Grab	N	N	1	250 ml Plastic	Lead	-23
24	HHS-1-FACULTY RM-BT-P	6:35	DW	Grab	N	N	1	250 ml Plastic	Lead	-24
25	HHS-1-NURSE-NS-P	6:40	DW	Grab	N	N	1	250 ml Plastic	Lead	-25
26	HHS-1-NURSE-IM-P	6:42	DW	Grab	N	N	1	250 ml Plastic	Lead	-26
27	HHS-2-H C212-BT-P	6:44	DW	Grab	N	N	1	250 ml Plastic	Lead	-27
28	HHS-2-C217 PREP-CF-P	6:46	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03290-28
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std.	PDF Reduce	PDF Full	EDD	Date/Time Preserved with (HNO ₃):
X				

Page 2 of 2

Deliverables:

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Agency:	Date + Time
Relinquished:	Marissa Weinstein	Marissa Weinstein	PARS	4/21/22
Received:	Collin Oriente	[Signature]	PARS	
Relinquished:	Collin Oriente	[Signature]	PARS	4/21/22
Received:	Lynn Souza	[Signature]	PARS	0945
Relinquished:				
Received:				