



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Marlboro high School, 95 N.Main Street
PAS Project ID : P22-03231

Matrix : Drinking Water
Report Date : 4/28/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03231-01	MAR-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:00	4/22/22 09:57
P22-03231-02	MAR-1-Custodial Break-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:03	4/22/22 10:01
P22-03231-03	MAR-1-Kit-FP1-P	Lead	6.71	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:05	4/22/22 10:35
P22-03231-04	MAR-1-Kit-FP2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:07	4/22/22 10:38
P22-03231-05	MAR-1-Kit-SP-P	Lead	18.5	ug/L	3	6.00	2.70	15.0 *	SM 3113 B	4/20/22 06:08	4/22/22 14:32
P22-03231-06	MAR-1-Kit-FP3-P	Lead	8.35	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:10	4/22/22 10:45
P22-03231-07	MAR-1-H B109-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:12	4/22/22 10:49
P22-03231-08	MAR-1-Trainer-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:13	4/22/22 10:53
P22-03231-09	MAR-1-Trainer-BF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:14	4/22/22 10:57
P22-03231-10	MAR-1-Trainer-HB-P	Lead	2.34	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:15	4/22/22 11:08
P22-03231-11	MAR-1-H C101-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:16	4/22/22 11:12
P22-03231-12	MAR-1-C103/Band-CF-P	Lead	33.5	ug/L	5	10.0	4.50	15.0 *	SM 3113 B	4/20/22 06:17	4/22/22 14:36
P22-03231-13	MAR-1-Nurse-NS-P	Lead	10.3	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:18	4/22/22 11:19
P22-03231-14	MAR-1-Nurse-IM-P	Lead	1.25 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:19	4/22/22 11:23
P22-03231-15	MAR-1-Nurse-BF-P	Lead	3.71	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:20	4/22/22 11:27
P22-03231-16	MAR-1-MO/Copy-TL-P	Lead	4.25	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:21	4/22/22 11:31
P22-03231-17	MAR-1-Main Entrance-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:22	4/22/22 11:34
P22-03231-18	MAR-1-H Media-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:29	4/22/22 11:38
P22-03231-19	MAR-1-A135-EC1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:30	4/22/22 11:53
P22-03231-20	MAR-1-A135-EC2-P	Lead	7.80	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:31	4/22/22 11:57
P22-03231-21	MAR-1-A135-EC3-P	Lead	0.980 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:32	4/22/22 12:00
P22-03231-22	MAR-1-A135-EC4-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:33	4/22/22 12:04
P22-03231-23	MAR-1-A135-EC5-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:34	4/22/22 12:08
P22-03231-24	MAR-1-A135-EC6-P	Lead	1.52 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:35	4/22/22 12:11
P22-03231-25	MAR-1-A133-EC1-P	Lead	1.25 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:36	4/22/22 12:15
P22-03231-26	MAR-1-A133-EC2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:37	4/22/22 12:18
P22-03231-27	MAR-1-A133-EC3-P	Lead	1.80 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:38	4/22/22 12:26
P22-03231-28	MAR-1-A133-EC4-P	Lead	2.89	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:39	4/22/22 12:40
P22-03231-29	MAR-1-A133-EC5-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:40	4/22/22 12:44
P22-03231-30	MAR-1-H A131-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:45	4/22/22 12:48
P22-03231-31	MAR-2-D Prep-1-CF-P	Lead	2.34	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:47	4/22/22 12:51
P22-03231-32	MAR-2-D Prep-4-CF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:48	4/22/22 12:55
P22-03231-33	MAR-2-A231 Prep-CF-P	Lead	698	ug/L	100	200	89.9	15.0 *	SM 3113 B	4/20/22 06:50	4/22/22 13:28
P22-03231-34	MAR-2-A230 Prep-CF-P	Lead	9.99	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 06:57	4/22/22 13:46
P22-03231-35	MAR-2-A227 Prep-CF-P	Lead	64.4	ug/L	10	20.0	8.99	15.0 *	SM 3113 B	4/20/22 06:59	4/22/22 14:22
P22-03231-36	MAR-2-H A229-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 07:00	4/22/22 13:53
P22-03231-37	MAR-2-E217A-CF-P	Lead	1.52 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 07:01	4/22/22 13:57
P22-03231-38	MAR-2-Dugout-DW-P	Lead	56.2	ug/L	10	20.0	8.99	15.0 *	SM 3113 B	4/20/22 07:04	4/22/22 14:25
P22-03231-39	MAR-2-Dugout-HB-P	Lead	6.44	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/20/22 07:06	4/22/22 14:29

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



CHAIN OF CUSTODY

Customer: PARS Environmental
 Address: 500 Horizon Drive, Suite 540
 Robbinsville, NJ 08691
 Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Parrini

School Name: Marlboro High School
 School Address: 95 N. Main Street
 Sampled By: Marissa Weinstein
 Print Name: Marissa Weinstein
 RESULTS TO: JPerrini@montrose-env.com

Sample #	Sample ID Location	Date: 4/20/22 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
1	MAR-FIELD BLANK	6:00	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03231-01
2	MAR-1-CUSTODIAL BREAK-TL-P	6:03	DW	Grab	N	N	1	250 ml Plastic	Lead	-02
3	MAR-1-KIT-FP1-P	6:05	DW	Grab	N	N	1	250 ml Plastic	Lead	-03
4	MAR-1-KIT-FP2-P	6:07	DW	Grab	N	N	1	250 ml Plastic	Lead	-04
5	MAR-1-KIT-SP-P	6:08	DW	Grab	N	N	1	250 ml Plastic	Lead	-05
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
6	MAR-1-KIT-FP3-P	6:10	DW	Grab	N	N	1	250 ml Plastic	Lead	-06
7	MAR-1-H BID9-BT-P	6:12	DW	Grab	N	N	1	250 ml Plastic	Lead	-07
8	MAR-1-TRAINER-IM-P	6:13	DW	Grab	N	N	1	250 ml Plastic	Lead	-08
9	MAR-1-TRAINER-BF-P	6:14	DW	Grab	N	N	1	250 ml Plastic	Lead	-09
10	MAR-1-TRAINER-HB-P	6:15	DW	Grab	N	N	1	250 ml Plastic	Lead	-10
11	MAR-1-H C101-BT-P	6:16	DW	Grab	N	N	1	250 ml Plastic	Lead	-11
12	MAR-1-C103/BAND-CF1P	6:17	DW	Grab	N	N	1	250 ml Plastic	Lead	-12
13	MAR-1-NURSE-NS-P	6:18	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03231-13

SAMPLES REC'D PRESERVED WITH HNO₃

Page 1 of 3

PDF Std. Reduce Full EDD

Deliverables: X

Date/Time Preserved with: (HNO₃)

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVAT IVE CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Marissa Weinstein	<i>Marissa Weinstein</i>	PARS	4/20/22
Received:	Collin Oriente	<i>Collin Oriente</i>	PARS	
Relinquished:	Collin Oriente	<i>Collin Oriente</i>	PARS	4/20/22
Received:	Lynn Souza	<i>Lynn Souza</i>	PARS	09:30
Relinquished:				
Received:				



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08793 PHONE 732-614-1516 FAX 732-614-1616

CHAIN OF CUSTODY

Customer: PARS Environmental
 Address: 500 Horizon Drive, Suite 540
 Robbinsville, NJ 08691
 Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Parrini

School Name: Marlboro High School
 School Address: 95 N. Main Street
 Sampled By: Mamina Weinstein
 Print Name: Marissa Weinstein
 RESULTS TO: jPerrini@montrose-env.com

Sample #	Sample ID Location	Date: 4/29/22 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
14	MAR-1-NURSE-IM-P	6:19	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03231-14
15	MAR-1-NURSEBF-P	6:20	DW	Grab	N	N	1	250 ml Plastic	Lead	-15
16	MAR-1-MO/COPY-TL-P	6:21	DW	Grab	N	N	1	250 ml Plastic	Lead	-16
17	MAR-1-MAIN ENTRANCE-BT-P	6:22	DW	Grab	N	N	1	250 ml Plastic	Lead	-17
18	MAR-1-H MEDIA-BT-P	6:29	DW	Grab	N	N	1	250 ml Plastic	Lead	-18
19	MAR-1-A135-EC1-P	6:30	DW	Grab	N	N	1	250 ml Plastic	Lead	-19
20	MAR-1-A135-EC2-P	6:31	DW	Grab	N	N	1	250 ml Plastic	Lead	-20
21	MAR-1-A135-EC3-P	6:32	DW	Grab	N	N	1	250 ml Plastic	Lead	-21
22	MAR-1-A135-EC4-P	6:33	DW	Grab	N	N	1	250 ml Plastic	Lead	-22
23	MAR-1-A135-EC5-P	6:34	DW	Grab	N	N	1	250 ml Plastic	Lead	-23
24	MAR-1-A135-EC6-P	6:35	DW	Grab	N	N	1	250 ml Plastic	Lead	-24
25	MAR-1-A133-EC1-P	6:36	DW	Grab	N	N	1	250 ml Plastic	Lead	-25
26	MAR-1-A133-EC2-P	6:37	DW	Grab	N	N	1	250 ml Plastic	Lead	-26
27	MAR-1-A133-EC3-P	6:38	DW	Grab	N	N	1	250 ml Plastic	Lead	-27
28	MAR-1-A133-EC4-P	6:39	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03231-28

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std. PDF Reduce PDF Full EDD

Page 2 of 3

Deliverables:

X

Date/Time Preserved with HNO₃:

MATRIX CODES:
 GW = Ground Water, WW = Waste Water, SW = Surface Water,
 DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge,
 B = Blank, K = Solid (specify):

PRESERVATION CODES:
 0 = Ice 1 = HCl
 2 = H2SO4 3 = NaOH
 4 = HNO3 5 = Other

	Print Name:	Signature:	Quantity	Date + Time
Relinquished:	Mamina Weinstein	MARISSA WEINSTEIN	PARS	4/20/22
Received:	Collin Oriente	<i>[Signature]</i>	PARS	
Relinquished:	Collin Oriente	<i>[Signature]</i>	PARS	4/20/22
Received:	Lynn Souza	<i>[Signature]</i>	PARS	09:30
Relinquished:				
Received:				



CHAIN OF CUSTODY

Customer: PARS Environmental
 Address: 500 Horizon Drive, Suite 540
 Robbinsville, NJ 08691
 Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

School Name: Marlboro High School
 School Address: 79 N Main Street
 Sampled By: Marissa Weinstein
 Print Name: Marissa Weinstein
 RESULTS TO: JPerrini@montrose-env.com

Sample #	Sample ID Location	Date: 4/29/22 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Fiber Present	# Containers	Glass or Plastic	Analysis	LAB ID
29	MAR-1-A133-ECS-P	6:40	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03231-39
30	MAR-1-HA131-BT-P	6:45	DW	Grab	N	N	1	250 ml Plastic	Lead	-30
31	MAR-2-DPREP-1-CF-P	6:47	DW	Grab	N	N	1	250 ml Plastic	Lead	-31
32	MAR-2-DPREP 4-CF-P	6:48	DW	Grab	N	N	1	250 ml Plastic	Lead	-32
33	MAR-2-A231 PREP-CF-P	6:50	DW	Grab	N	N	1	250 ml Plastic	Lead	-33
34	MAR-2-A230 PREP-CF-P	6:57	DW	Grab	N	N	1	250 ml Plastic	Lead	-34
35	MAR-2-A227 PREP-CF-P	6:59	DW	Grab	N	N	1	250 ml Plastic	Lead	-35
36	MAR-2-HA 229-BT-P	7:00	DW	Grab	N	N	1	250 ml Plastic	Lead	-36
37	MAR-2-E217A-CF-P	7:01	DW	Grab	N	N	1	250 ml Plastic	Lead	-37
38	MAR-1-DUGOUT-DW-P	7:04	DW	Grab	N	N	1	250 ml Plastic	Lead	-38
39	MAR-1-DUGOUT-HB-P	7:06	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03231-39
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std. Reduce Full EDD

Date/Time Preserved with HNO₃:

Page 3 of 3 Deliverables: X

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Agency:	Date + Time
Relinquished:	Marissa Weinstein	Marissa Weinstein	PARS	4/20/22
Received:	Collin Oriente	[Signature]	PARS	
Relinquished:	Collin Oriente	[Signature]	PARS	4/20/22
Received:	Lyna Souza	Lyna Souza	PAS	09:30
Relinquished:				
Received:				