



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Transportation, 117 Crow Hill Road
PAS Project ID : P22-03291

Matrix : Drinking Water
Report Date : 5/2/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03291-01	TRANS-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 07:30	4/22/22 14:40
P22-03291-02	TRANS-1-Driver Rm-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 07:35	4/22/22 14:43
P22-03291-03	TRANS-1-Shop Lunch Rm-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 07:37	4/22/22 15:41
P22-03291-04	TRANS-1-Office-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/21/22 07:40	4/22/22 15:45

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal
PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-614-1516 FAX 732-614-1616

CHAIN OF CUSTODY

1079-10

Customer:	PARS Environmental
Address:	500 Horizon Drive, Suite 540
	Robbinsville, NJ 08691
Phone:	(609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

School Name:	Trans Portation
School Address:	117 Crow Hill Road
Sampled By:	Marissa Weinstein
Print Name:	Marissa Weinstein
RESULTS TO:	JPerrini@montrose-env.com

Sample #	Sample ID Location	Date: 4/21/22 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Preserv	# Containers	Glass or Plastic	Analysis	LAB ID
1	TRANS-FIELD BLANK	7:30	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03291-01
2	TRANS-1-DRIVER RM-TL-P	7:35	DW	Grab	N	N	1	250 ml Plastic	Lead	-02
3	TRANS-1-SHOP LUNCH RM-TL-P	7:37	DW	Grab	N	N	1	250 ml Plastic	Lead	-03
4	TRANS-1-OFFICE-TL-P	7:40	DW	Grab	N	N	1	250 ml Plastic	Lead	P22-03291-04
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	

SAMPLES REC'D PRESERVED WITH HNO₃

PDF Std.	PDF Reduce	PDF Full	EDD	Date/Time Preserved with HNO ₃ :
X				

Page 1 of 1

Deliverables:

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Marissa Weinstein	Marissa Weinstein	PARS	4/21/22
Received:	Collin Oriente	Collin Oriente	PARS	
Relinquished:	Collin Oriente	Collin Oriente	PARS	4/21/22
Received:	Lynn Souza	Lynn Souza	PARS	0945
Relinquished:				
Received:				